From: Knudsen, Cynthia J (DFW)
To: Mendoza, Sonia (ECY); SEPADesk2 (DFW)
Cc: Robertson, Julie (ECY); Cornett, Deborah (ECY); Smith, Joyce M. (ECY)
Subject: RE: ECY SEPA 14-0877 - Lynch Cove Demolition project - Comments
Date: Tuesday, March 11, 2014 10:14:47 AM

Ecology SEPA 14-0877
Lynch Cove Demolition Project
Thank you for your comments for the Lynch Cove Demolition project.

TO: Julie Robertson
Ecology Waste to Resources contact

Inspections have been done by certified asbestos abatement and lead paint inspectors. Demolition materials will be disposed of in an approved manner (including PCB-containing lamp ballasts, florescent lamps and wall thermostats containing mercury). The demolition materials will be removed before demolition, and managed properly after removing from the demolition site. The "Dangerous Waste Rules for Demolition, Construction and Renovation Wastes" information will be referred to as a guide for demolition operations.

TO: Deborah Cornett
Ecology Water Quality Contact

WDFW realizes that discharge of sediment laden water is in violation of Chapter 90.48 RCW Water Pollution Control and WAC 173-201A, and subject to enforcement action. Debris will be disposed of in a manner that they cannot enter the waters of the state. There are no storm drains anywhere near the demolition sites. Best Management Practices will be used to prevent degradation of state waters buy using perimeter controls such as filter fence, hay bales, and straw wattles and or sediment basins.

The two conditions requiring a NDPES permit are not met for this project. Each of the sites are separated from each other and they are each less than one acre. These sites follow natural discharge patterns to ground from the structures. No storm drains are anywhere near the structures. No off site discharge is anticipated from the demolition project. All appropriate BMPs will be used to prevent off site discharge.

Thank you for your comments.
Cindy Knudsen

Cindy Knudsen
Washington State Fish and Wildlife
Fish and Wildlife Biologist - Permitting
600 Capitol Way North
Olympia, WA. 98501
Phone: 360 902 8422
cindy.knudsen@dfw.wa.gov

From: Mendoza, Sonia (ECY)
Sent: Friday, March 07, 2014 1:37 PM
To: SEPADesk2 (DFW)
Cc: Robertson, Julie (ECY); Cornett, Deborah (ECY); Smith, Joyce M. (ECY); Knudsen, Cynthia J (DFW)
Subject: ECY SEPA 14-0877 - Lynch Cove Demolition project - Comments
Importance: High

Ms. Wood,
Attached are Ecology's comments for the Lynch Cove Demolition project (Ecology SEPA No. 14-0877). Comments are due today 3/7/14.

Attached is the original final copy.

Please reply to this message for confirmation. Thank you.

Sonia Mendoza
Department of Ecology-SWRO
SEPA Coordinator
P:360-407-6313 **| F:**360-407-6305
sonia.mendoza@ecy.wa.gov
Please consider the environment before printing this e-mail