

From: [Sample, Anna Marie E \(DFW\)](#)
To: [ECY RE CRO SEPA Coordinator](#)
Cc: [SEPADesk2 \(DFW\)](#)
Subject: FW: Comments for DNS 19-062
Date: Tuesday, December 31, 2019 1:23:59 PM
Attachments: [201907064_DNR.pdf](#)
[Wells WLA Launch Drawings.pdf](#)
Importance: High

Hello Gwen,

Thank you for your comment and review of the Wells Recreation Site Development project. This project proposes to make upgrades to an existing gravel boat launch and parking area on the WDFW Wells Wildlife Area, providing public access to the Columbia River. The existing gravel impervious surface amount is 7,253 sq ft (0.16 acre) and will be expanded (graded) to 10,101 sq ft (.23 acre) in the proposed upgrade. See Sheet 5 of the attached drawing set. The project site is under an acre in size and is not part of a larger common plan of development, so the Construction Stormwater General Permit (CSWGP) is not required for this proposal. The use of BMPs such as straw wattles and a silt curtain will be in place during construction, see sheet 4 of the attached drawing set.

Thank you again for your review of this project.

Happy New Year!

Anna

Anna Marie Sample

Biologist 3 Capital and Asset Management Program

600 Capital Way N Olympia, WA 98501 **Washington Department of Fish and Wildlife**

AnnaMarie.Sample@dfw.wa.gov Cell: (360) 790-0868 *-call or text-*

From: ECY RE CRO SEPA Coordinator <crosepa@ecy.wa.gov>

Sent: Monday, December 23, 2019 1:18 PM

To: SEPADesk2 (DFW) <SEPADesk2@dfw.wa.gov>

Subject: Comments for DNS 19-062

Importance: High

Please see the attached comment letter for the Wells Recreation site development.

Thank you

Gwen Clear

WA State Dept. of Ecology
Regional SEPA Coordinator
1250 W. Alder Street
Union Gap, WA 98903-0009
(509) 575-2012
crosepa@ecy.wa.gov