

From: [ECY RE CRO SEPA COORDINATOR](#)
To: [SEPADesk2 \(DFW\)](#)
Subject: additional comments for Wenner Lake/Benson Creek Irrigation Repair DNS 16-060
Date: Wednesday, October 05, 2016 10:11:02 AM

Please see below comment from Ecology's Dam Safety program - these comments are in addition to Ecology's comment letter dated October 4, 2016.

Under RCW 90.03.350, a Dam Safety construction permit is required for those dams which impound a volume of 10 acre-feet or more of water or other liquids above ground level. To determine if a Dam Safety construction permit is required for your project, please submit a set of construction plans to:

Martin Walther, P.E.
WA Department of Ecology
Dam Safety Office
P.O. Box 47600
Olympia, WA 98504-7600

For more information, please contact Martin Walther by e-mail at mwal461@ecy.wa.gov or by telephone at (360) 407-6420.

Thank you,
Gwen Clear
Regional SEPA Coordinator
1250 W. Alder Street
Union Gap, WA 98903-0009
(509) 575-2012