

**From:** [Sample, Anna Marie E \(DFW\)](#)  
**To:** [ECY RE SWRO SEPA COORDINATOR; SEPADesk2 \(DFW\)](#)  
**Cc:** [Davis, Tara \(ECY\); Kourehdar, Mohsen \(ECY\)](#)  
**Subject:** RE: ECY SEPA 201800250 - Ward Lake Access Site Improvements - Comments  
**Date:** Thursday, February 01, 2018 3:36:56 PM  
**Attachments:** [image004.png](#)

---

Thank you for reviewing the Ward Lake Access Site Improvements project and providing your comment.

The two buildings we plan to remove are vault toilet buildings that were pre-fabricated and used as the standard for WDFW on many Water Access sites around the state. Many of these outdated vault toilet buildings have been removed and upgraded at Water Access sites throughout the state to allow ADA accessibility.

We have received confirmation from the Olympic Region Clean Air Agency (ORCAA) that, given the specs of these vault toilet buildings, an asbestos survey is not required for demolition. There are no hazardous waste materials, such as PCB-containing lamp ballasts, fluorescent lamps, or wall thermostats containing mercury, present at the work site.

The vaults of each of the toilet buildings will be pumped of sewage prior to demolition. All structural materials from the existing vaults and toilet buildings will be disposed of at an appropriate waste facility.

Thank you again for your comment.  
Anna Sample

### **Anna Marie Sample**

**Biologist** Capital and Asset Management Program  
600 Capital Way N Olympia, WA 98501 • **Washington Department of Fish and Wildlife**  
[AnnaMarie.Sample@dfw.wa.gov](mailto:AnnaMarie.Sample@dfw.wa.gov) • Office: (360) 902-8429



---

**From:** ECY RE SWRO SEPA COORDINATOR  
**Sent:** Thursday, February 1, 2018 2:31 PM  
**To:** SEPADesk2 (DFW) <SEPADesk2@dfw.wa.gov>  
**Cc:** Sample, Anna Marie E (DFW) <AnnaMarie.Sample@dfw.wa.gov>; Davis, Tara (ECY)

<TDAV461@ECY.WA.GOV>; Kourehdar, Mohsen (ECY) <mkou461@ECY.WA.GOV>

**Subject:** ECY SEPA 201800250 - Ward Lake Access Site Improvements - Comments

**Importance:** High

Ms. Wood,

Attached are Ecology's comments for the Ward Lake Access Site Improvements Project (Ecology SEPA No. 201800250). This is the original final copy. Comments are due today 2/1/18.

**Please reply to this message for confirmation.**

*\*Please use the correct acronym "ECY" for the Department of Ecology (DOE is US Department of Energy).\**

Sonia Mendoza  
Department of Ecology  
Federal Permit & SEPA Unit  
(360) 407-7676