



NOTES:

1. ENTIRE ASSEMBLY SHALL BE CONSTRUCTED OF FIBERGLAS LAMINATE, 25% MIN. GLASS CONTENT.
2. WALLS & STOOL SHALL BE MINIMUM .125 INCH THICKNESS, TRANSLUCENT ROOF SHALL BE .1875 INCH THICKNESS.
3. INTERIOR WALLS, STOOL EXTERIOR & URINAL INTERIOR SHALL BE WHITE GEL KOTE.
4. EXTERIOR SHALL BE WOOD GRAIN BROWN GEL KOTE.
5. MEN'S UNIT SHOWN. WOMEN'S UNIT SIMILAR EXCEPT OMIT URINAL ASSEMBLY.
6. USE WASHERS UNDER ALL FASTENERS SEATED ON PLASTIC SURFACES.
7. TOLERANCE ON DIMENSIONS: LINEAR = ± 1/16 ; RADII = ± 1/32

DATE	DESCRIPTION
4-4-73	ADDED PAD & 1/2" AROUND DOOR OPENING; REV. STOOL HT.; ADDED URINAL HOLDER; REV. MFG.
STATE OF WASHINGTON DEPARTMENT OF FIBERGLAS CHEMICALS TOILET ASSEMBLY	
<p>GLYN E. STEINER CHIEF ENGINEER CARL W. CROOK DIRECTOR P.E. & M.C. 318 PROJECT NO.</p>	<p>DESIGNED BY _____ SURVEY _____</p> <p>DRAWN BY SRT DATE _____</p> <p>CHECKED BY RID BOOK NO. _____</p>